

**ADDENDUM ONE**  
**CONTRACT NO: E-5J19**  
**FINANCIAL NOS.: 415783-1-72-02 (Maintenance)**  
**413809-1-52-02 (Construction)**  
**COUNTIES: Lake, Sumter, Seminole and Orange**  
**PREQUALIFICATION: Pavement Marking**  
**LETTING DATE: May 02, 2006**

**QUESTION:**

The above referenced contract currently out to bid is comprised of both construction and maintenance components. Under the new 711 Thermoplastic Specifications (revised 01/06), this construction/maintenance combination presents a problem in that one pay item can no longer be used to cover both types of work. For example, Contract E5J19 has one pay item for 12" White Thermo, the quantity of which is broken down by 10,796 LF for construction (initial), and 6,657 LF for maintenance (refurbish). Under the new 711 specs, the initial portion will be installed at a minimum of 100 mils, and the refurbish portion will be installed at a minimum of 60 mils. This 40 mil difference represents a significant cost differential between the two line types, and any variance between the bid and actual quantities could have a serious financial impact.

There are ten pay items in this contract that are effected by this problem (i.e. have both construction and maintenance quantities). A solution would be to add a second pay item for each of these ten line types, and specify one for construction (initial) and one for maintenance (refurbish). This dual pay item strategy would have to be used whenever the DOT is asking for both initial and refurbish line types within the same contract. On July 1, 2006 the new basis of estimates will be out with a new pay item structure that should solve this problem.

Chester Henson (Roadway Design Office in Tallahassee) has led the development of the new 711 specs and he would be able to answer any questions you may have concerning them. Please let me know if I can help.

**ANSWER:**

Bid all thermoplastic items, both maintenance and construction, using specification 711-2.1.1 Initial or Recapped Stripes and Markings. Placement and acceptance criteria for construction and maintenance thermoplastic items will be based on specification 711-2.1.1.

Bid all Hot Spray items using specification 711-2.1.2 Refurbishing existing Stripes and Markings. Placement and acceptance of Hot Spray items will be based on specification 711-2.12.

Please respond by signing below and faxing a copy back to (386) 740-4208. If you have any questions, please call me at the number below.

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date